



Fraunhofer

TESTED[®] DEVICE

REGIOLUX GmbH
ADAMP/1500 LED 12500 IPA
Report No. RE 2011-1189

Single product
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

Regiolux GmbH
Königsberg, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RE 2011-1189.

The luminaire ADAMP/340-1500 LED 12500 940 DALI IP65 (color: traffic white) is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

Suitability

up to GMP Class D

The recommendation takes the existing of the PE foam seal into consideration, which slightly jut out over the edge of the luminaire. A release of particles can be observed at this point.

However, this recommendation only pertains to the operating utility when in a resting state. An overall assessment of the ADAMP/340-1500 LED 12500 940 DALI IP65 can only be made after its installation in the production area.

RE 2011-1189
Report No. first document

Stuttgart, April 19, 2021
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.